



DEPARTMENT OF THE ARMY  
SAN FRANCISCO DISTRICT, U.S. ARMY CORPS OF ENGINEERS  
450 GOLDEN GATE AVENUE  
SAN FRANCISCO, CALIFORNIA 94102

## PUBLIC NOTICE

### REQUEST TO ALTER US ARMY CORPS OF ENGINEERS CIVIL WORKS PROJECT PURSUANT TO 33 USC 408 (SECTION 408)

**Section 408 Request ID:** 408-SPN-2021-0004

**Requester:** Santa Clara Valley Water District

**Alteration Being Proposed:** Repair stormwater outfall #67F and 509 along the Guadalupe River in the City of San Jose.

**Description of Alteration:** Repair for outfall #67F involves the removal of an existing 30-inch diameter storm outfall structure and pipe and replacement with a 72-inch diameter storm sewer outfall pipe connecting to a new 72-inch diameter outfall with flap gate. Repair for outfall #509 involves removing approximately 15ft of the existing 66-inch CMP outfall and replaced with 15 ft of new 66-inch concrete pipe. A drop manhole will also be installed.

**Location of Alteration:** Outfall #67F is located on the west bank of the Guadalupe River just upstream of Coleman Avenue, at the east end of vacated Howard Street. Outfall #509 is located downstream of outfall #67F, on the east bank of Guadalupe River downstream of Coleman Avenue.

**Comment Period Expires:** March 30, 2021

**Submitting Comments:** Please submit written comments by March 30, 2021 to the following address.

Holly Costa  
Emergency Management Chief  
U.S. Army Corps of Engineers, San Francisco District  
Emergency Operations Center  
2100 Bridgeway  
Sausalito, California 94965

Email: [Holly.N.Costa@usace.army.mil](mailto:Holly.N.Costa@usace.army.mil)